

S3 COMMUNICATION **ALARM**



Part No. 11-930-CA



Part No. 11-930-CAA

DESCRIPTION

Wurtec's S3 Communication Alarm is designed to comply with code A17.1-2016, Section 2.27.1.1.6, which states,

"If the telephone line or equivalent means is not functional, an audible and illuminated visual signal shall be activated. A minimum of one visual and one audible signal shall be provided for each group of elevators controlled by a 'FIRE RECALL' switch."

The S3C Communication Alarm works seamlessly with our entire line of S3C building-powered phones. Mounted in the fire control panel, the alarm will buzz and flash briefly every 30 seconds when a phone line failure is detected. The audible and visual notification will continue until the phone line is restored, or until the S3C Communication Alarm is manually switched off.

Wurtec also offers the S3C Communication Alarm Assembly, which includes the S3 Communication Alarm, a fire hat indicator light, and a momentary silencing key switch, all prewired and installed in a self-contained enclosure.

Part No.	Description
11-930-CA	S3C Communication Alarm
11-930-CA-2SEC	S3C Communication Alarm, 2 Second Pulse
11-930-CAA	S3C Communication Alarm Assembly
11-930-CA-RB	Alarm Board w/ Remote Battery to Accommodate Smaller Enclosures